

Motor Vehicle Exhibition Requirements Information Sheet

Motor vehicles on display within an exposition building or tent shall comply with the following:

- a) All fuel tank openings shall be locked and sealed in an approved manner to prevent the escape of vapors. Fuel tanks shall not be more than one-half full or contain more than 10 gallons of fuel; whichever is less.
- b) At least one battery cable shall be removed from the batteries used to start the vehicle engine. The disconnected battery cable shall then be taped.
- c) Batteries used to power auxiliary equipment are permitted for service.
- d) Fueling or de-fueling of vehicles shall be prohibited within the facility.
- e) Motor vehicles shall not be moved during show hours or when the general public is present.
- f) Approved aisles and a means of egress shall be maintained throughout the exhibition area.

Note: A Temporary Fire Marshal Permit shall be obtained for each event. The fee for this permit is \$39.

Questions?

Contact the City of Bloomington,
Fire Prevention Division, at 952-563-8933
or Fire Marshal Gene Dugal
at 952-563-8967.

